

STATE UNIVERSITY CONSTRUCTION FUND PROGRAM DIRECTIVES

DIRECTIVE 15P-3

Issue date: October 2012

FLOOR DRAINS and FLOOR RECEPTORS

1. Design and Performance Criteria
 - a. In order to prevent water puddling on floors, consultants are to include in their design drawings and/or specifications, specific instructions that floors are to be pitched to drains.
 - b. Equipment rooms are to be furnished with drains near all major equipment that must be periodically drained. Funnel drains may be required for splash control.
 - c. On each floor, provide at least one floor receptor in all academic buildings, located in a janitor's closet.
 - d. Receptors are to be used for dumping water from the floor cleaning machines. Verify equipment requirements with the campus. A watertight curb approximately 8" high should be provided.

* * * * *