



SUMMARY

This Directive provides the consultants with the requirements of the SUNY Construction Fund for all projects across the SUNY State Campuses. The requirements below are to be implemented into the design of the project. The implemented requirements are to be clearly called for in the project specifications, drawings, or both. The Specifications or Drawings are to describe or show the requirement. The intent is not for the Specifications or Drawings to reference back to this document for compliance.

In addition to state and local codes and standards, the following requirement listed below are to be included in the contract documentation. The intent of this document is not to override or amend the local or state codes where such are more stringent. The drawings and specifications must comply with the Code (see Directive 1B-1 Building Codes).

TABLE OF CONTENTS

Contents

Section 1 - APPLICABILITY	3
Building Code	3
LEED	3
NYSERDA or other incentive programs.....	3
Section 2 - RESPONSIBILITIES OF COMMISSIONING PARTICIPANTS	3
Section 3 - QUALIFICATIONS OF THE COMMISSIONING AUTHORITY (CXA).....	4
Section 4 - COMMISSIONING.....	4
Section 5 - DELIVERABLES.....	6
Commissioning Plan	6
Commissioning Specification	6
Operations and Maintenance Manual.....	6
Systems Manual	7
Commissioning Report	7
Section 6 - TRAINING	8

Section 1 - APPLICABILITY

Building Code

1. Commissioning as required to comply with the requirements of the New York State Energy Conservation Code (NYSECCC) section C408 with the NYStretch Energy Code – 2020 modifications. This includes all new construction, additions or alterations to existing buildings and systems.
 - a. Systems to be Commissioned: Building envelope, building mechanical systems, service water heating systems, and electrical power and lighting systems. The following systems must be commissioned:
 - i. Chiller, air conditioner, heat exchangers, campus chilled water, condensers, cooling systems
 - ii. Boiler, furnace, heat exchangers, steam, HTHW, MTHW, heating systems
 - iii. Domestic and service water heater, domestic water heating systems
 - iv. Cooling tower (fan, valves)
 - v. Air Handling Unit (coils, valves, fans, humidification, dampers)
 - vi. HVAC terminal units (fan coil units, heat pumps, VAV, etc.)
 - vii. Ventilation, exhaust, and miscellaneous fans
 - viii. Ducts and dampers
 - ix. Piping and valves
 - x. Duct and piping insulation
 - xi. Controls for system, building and central plant.
 - xii. Energy recovery (components, systems and units).
 - xiii. Air or water economizers
 - xiv. Renewable energy systems
 - xv. Thermal storage
 - xvi. HVAC pumps
 - xvii. Refrigerant leak detection systems
 - xviii. Fume hood and other special exhaust systems
 - xix. Electrical systems and lighting systems including daylight/occupancy sensor and dimming controls
 - xx. Building Envelope – Follow current code referenced ASHRAE 90.1 Inspection and verification section requirements. Air leakage verification of the air barrier shall be done utilizing the design and installation verification program option excluding whole-building pressurization testing.
 - xxi. Any other equipment of systems used for HVAC that affect energy use or indoor air quality, or the campus ability to operate a building for its intended use
 - xxii. Any other system as requested by the design team and approved by SUCF

LEED

1. Commissioning as required to achieve selected LEED credits including documentation as required for and filling out of LEED templates for commissioning credits.

NYSERDA or other incentive programs

1. Commissioning as required to meet the requirements of selected NYSERDA programs or any other incentive program used by the project

Section 2 - RESPONSIBILITIES OF COMMISSIONING PARTICIPANTS

1. Designer of systems to be commissioned must prepare a written description of each system's owners project requirements (OPR), basis of design (BOD), and sequence of operations. Development of OPR and

BOD shall include a review by the project's commissioning authority. These items shall be submitted with the Design Manual Phase submission.

- a. The Owners Project Requirements (OPR) document shall detail the basics of the system(s) that are to be commissioned. It shall include but not be limited to: Service water heating criteria, lighting systems design, space temperature and humidity criteria, thermal zoning criteria, level of occupant control over HVAC systems, ventilation and IAQ criteria, performance related to energy efficiency, and commissioning criteria.
 - b. The Basis of Design (BOD) document shall layout the decisions made to meet building program requirements. The BOD details systems, conditions, methods, and components chosen to meet the OPR. The BOD must include the following: occupancy, space climate requirements, applicable codes and standards, primary load and design assumptions, LEED elements, lighting levels and controls, energy performance, ventilation strategies and methods, control systems complete with sequence of operations, fire and life safety criteria, emergency power control and function, and additional information that will aid in the commissioning process or future building operation.
 - c. In addition to submitting the OPR and BOD to SUCF for review during the design process, the OPR and the BOD must be included in the Commissioning Reports and System Manual.
2. Commissioning authority shall lead, plan, schedule and coordinate the process of verifying and documenting that the facility and its systems are planned, designed, installed, tested, operated, and maintained to meet the OPR.

Section 3 - QUALIFICATIONS OF THE COMMISSIONING AUTHORITY (CXA)

1. CxA must have documented commissioning project experience on at least two building projects with a similar scope of work. The experience must extend from early design phase through initial occupancy.
2. CxA may be an independent consultant or a disinterested subcontractor of the design team.

Section 4 - COMMISSIONING

1. The commissioning authority must:
 - a. Review and approve the designer's OPR, BOD and sequence of operations.
 - b. Review design documents, at or before the Design Manual submission for their impact on the commissioning process and the final performance of the commissioned systems. This review shall ensure that adequate devices are included in the design to properly document the performance of the commissioned systems and equipment. The review shall confirm that the BOD is reflected in the design documents and meets the OPR.
 - c. Develop/review and approve the following written products:
 - i. Develop commissioning specifications.
 - ii. Develop design phase commissioning plan.
 - iii. Develop construction phase commissioning plan.
 - iv. Review contractor submittals of commissioned systems/equipment.
 - v. Develop/review and approve installation verification checklists, and pre-functional checklists.
 - vi. Develop/review functional performance testing procedures and checklists.
 - vii. Review/approve testing, adjusting, and balancing (TAB) plan.
 - viii. Review/approve equipment/system training requirements during design.
 - ix. Review/approve Operations and Maintenance Manual as submitted by the contractor.
 - x. Develop Commissioning Operations Manual
 - xi. Develop Systems Manual requirements and include in bid documents
 - xii. Develop Systems Manual

- xiii. Develop Commissioning Report.
- xiv. Develop an ongoing Commissioning Plan.
- xv. Review building envelope for compliance with OPR and BOD.
- d. Using the Installation Verification and Pre-functional Checklists, the commissioning authority shall, with the assistance of the contractor, verify and document the installation of systems, equipment, and components. The commissioning authority shall be the responsible party to obtain contractor signatures and to fill out installation checklists and pre-functional tests. The commissioning authority shall also be responsible to maintain an up-to-date commissioning report at the site. Any differences between original construction documents and final installation must be documented in the report. Documentation shall also be provided for other building systems or components that may be compromising the efficiency of the systems or features being commissioned.
- e. The commissioning authority shall also be responsible party to oversee functional testing performed by the contractor and to fill out the functional performance checklists and procedures for insertion in the commissioning report.
- f. Commissioning shall be performed on 100% of all main/central equipment and systems. Sampling strategies are allowed during Functional testing only on terminal equipment. (i.e., fan coils or non-laboratory VAV boxes.) Sampling shall incorporate 20% of terminal equipment or 10 units minimum. If functional issues are discovered an additional 10% shall be added until the terminal units pass functional testing and are functioning according to the BOD.
- g. Provide timely reporting and distribution of the findings, as required to minimize the volume of submissions submitted for owner information and review. Provide frequent updates to the status of activities and facilitate owner review of progress and status reports such as through electronic or online access to forms, with changes flagged by date.
- h. Witness all or part of the:
 - i. HVAC piping tests and flushing procedures
 - ii. HVAC duct tests and cleaning procedures
 - iii. Sufficient functional testing of the control system to approve its use for TAB, before TAB is executed.
- i. Visit and inspect the construction site, participate in project design review meetings, and telephone conference calls with SUCF, its contractors and consultants, and the campus, as required to effectively provide commissioning services.
- j. Early in the construction process meet with the General Contractor (GC) and Construction Manager (CM) to incorporate commissioning activities into the construction schedule.
- k. Conduct construction commissioning kickoff meeting, with all commissioning team members in attendance to review the process and requirements for all commissioning activities through owner occupancy.
- l. Conduct regular commissioning meetings with commissioning team throughout construction. Once a month at beginning of project, progressing to once a week as the project moves into the functional testing phase. Provide written meeting minutes.
- m. Oversee and approve the training of the owner's personnel.
- n. Maintain a master log of deficiencies and resolutions and maintain a separate testing log.
- o. Return to the site 10 months after building occupancy to review building operation and original commissioning, and for seasonally deferred testing.

Section 5 - DELIVERABLES

Commissioning Plan

1. Commissioning plan must be written around using a single prime contractor. Terms such as “Mechanical Contractor”, “Plumbing Contractor”, “Electrical Contractor” and “Controls Contractor”, etc. shall not be used.
2. Commissioning should be done in two separate but related parts. Commissioning Plan–Design Phase and Commission Plan–Construction Phase. Each plan must include, but is not limited to:
 - a. Overview of tasks to be executed.
 - b. List of all systems and features to be commissioned.
 - c. Simulation of various operational conditions and scenarios that could be anticipated to occur in each space.
 - d. List of all reference documents, i.e., specifications, drawings, and submittals.
 - e. List of participants and their responsibilities.
 - f. A plan for management, communication, and documentation.
 - g. Outline of the scope of the commissioning process including seasonally deferred testing.
 - h. Description of checklists and tests to be performed for pre-start and start-up.
 - i. A list of functional performance tests.
 - j. Description of the verification process used to document the process.
 - k. Description of the content of the training to be provided to the facility personnel.
 - l. An activity schedule.
 - m. Method to document changes and incorporating changes in as-built record

Commissioning Specification

1. Commissioning plan must be written around using a single prime contractor. Terms such as “Mechanical Contractor”, “Plumbing Contractor”, “Electrical Contractor” and “Controls Contractor”, etc. shall not be used.
2. Must be included in the Construction Documents, and must include:
 - a. Scope and details of the process.
 - b. Qualifications required by the Commissioning Agent.
 - c. Roles and responsibilities of all parties involved in commissioning process.
 - d. Systems, equipment, and components to be commissioned.
 - e. Pre-functional checklist and start-up requirements.
 - f. Functional performance testing requirements, including test conditions and acceptance criteria.
 - g. Procedures for resolving deficiencies.
 - h. Reporting and documentation requirements.
 - i. Training requirements.
 - j. Operations and maintenance manuals requirements.
 - k. Proposed schedule of activities.
 - l. Definition of the minimum requirements for the Contractor’s coordination and management plan (the need for a single person employed by Contractor to coordinate work of subcontractors, staff qualifications, etc.).

Operations and Maintenance Manual

1. Must be complete and fully cover all systems commissioned. At a minimum the O&M manual(s) must include, for all equipment:
 - a. System narrative of how each system is intended to operate.
 - b. Vendor location and contact information.

- c. Name and address of one service agency.
- d. Project-specific submittal information.
- e. Operations and maintenance instructions for specific model (Only information for equipment installed shall be included).
- f. Installation and startup instructions.
- g. Schedule for inspecting and recalibrating all lighting controls.
- h. Parts list and special tool list.
- i. Performance data (pump, fan curves).
- j. Warranty information.
- k. As-built data for control systems to document actual control schemes and sequences used. Include sequence of operations, runtime schedules, setpoints, lighting levels, minimum outside air values, wiring diagrams, and schematics. Documents shall have all field determined setpoints permanently recorded at control devices and in system programming instructions.

Systems Manual

1. Must be project specific and must contain at a minimum:
 - a. Executive Summary.
 - b. A narrative of the BOD and OPR (modified to reflect the as-constructed installations) which shall include a brief description of the systems.
 - c. Construction Record Drawings and specifications.
 - d. Final Commissioning plan and the Final Commissioning report.
 - e. Operations and Maintenance Manual.
 - f. A detailed description of energy saving features and options as well as a description of their special maintenance requirements.
 - g. Recommendations and methodology for accounting of building energy usage.
 - h. Recommendations for frequency of sensor and actuator recalibration.
 - i. Recommendations for frequency of recommissioning of specific systems (i.e., CO₂ controlled outdoor air system).
 - j. List and description of user adjustable set points and schedules with recommendations for adjustments.
 - k. List of system diagnostic tools (i.e., trend logs) to be used by operators in optimizing building energy efficiency.

Commissioning Report

1. Preliminary & Final Report must be project specific and completed after all commissioning except seasonally deferred testing. Report must include:
 - a. Executive Summary.
 - b. List of all commissioning participants and their roles.
 - c. Brief building description.
 - d. Overview of commissioning scope, testing and verification methods.
 - e. List of commissioned systems.
 - f. Description of adequacy of training, installation, functional performance, efficiency, equipment documentation, and O & M manuals.
 - g. List of outstanding commissioning issues and statement as to why item is outstanding. (i.e., installation deficiency, seasonally deferred testing, etc.) Each outstanding commissioning item shall be referenced to where deficiency is documented in the commissioning plan and shall lay out the path/schedule as to when commissioning will take place.
 - h. Appendices with commissioning plans, installation checklists, pre-functional tests, functional tests, individual commissioning reports or reviews, sequence documentation, logs, meeting

minutes, progress reports, deficiency logs, site visit reports, photos, findings, unresolved issues, communications, and other relevant project information.

- i. A list of as-built components, equipment, systems, controls, and sequences of operation that is different than required in the original construction documents.
 - j. Commissioning authority shall issue an addendum to the commissioning report (if necessary) to complete the commissioning report for seasonally deferred testing or deficiency resolution to commissioned systems.
2. Training documentation as detailed below.

Section 6 - TRAINING

1. Prior to contractor training the CxA shall meet with owner and owner personnel to be trained to review all commissioning deliverables.
3. The commissioning authority must document that training (both instructional and demonstration) of operations and maintenance personnel was conducted for all commissioned systems. The commissioning agent shall oversee and approve the content and adequacy of the training for commissioned systems.
4. The Owner will identify the personnel to be trained.
5. Training must be performed within three (3) months of the date commissioning is completed on the system.
6. The Operations and Maintenance Manual and the Systems Manual must be available and used for the training.
7. The instructional portion of the training must cover, at a minimum:
 - a. General description of systems, theory of operation, control modes, and sequences of operation.
 - b. Use of the Operations and Maintenance as well as System Manuals.
 - c. Review of control diagrams and drawings.
 - d. Use of building controls system, including startup, shutdown, seasonal changeover, alarms, troubleshooting, set-up, and data logging/trending.
 - e. Service and operations of each system.
 - f. Specific training on building systems which effect energy consumption, indoor air quality and occupant comfort.
8. The demonstration portion of the training must include hands-on operation of systems and/or equipment for which instructional training will be given. Start-up, shut-down procedures, operation under all sequence of operations and emergency conditions.